



UNITED STATES PATENT AND TRADEMARK OFFICE

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office
Address: COMMISSIONER FOR PATENTS
P.O. Box 1450
Alexandria, Virginia 22313-1450
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
10/662,945	09/15/2003	Thomas F. Papallo	138561	2025

7590

01/24/2006

Paul D. Greeley, Esq.
Ohlandt, Greeley, Ruggiero & Perle, L.L.P.
One Landmark Square, 10th Floor
Stamford, CT 06901-2682

EXAMINER

CABRERA, ZOILA E

ART UNIT

PAPER NUMBER

2125

DATE MAILED: 01/24/2006

Please find below and/or attached an Office communication concerning this application or proceeding.

Office Action Summary

Application No.

10/662,945

Applicant(s)

PAPALLO ET AL.

Examiner

Zoila E. Cabrera

Art Unit

2125

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --

Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS, WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

Status

- 1) ☒ Responsive to communication(s) filed on 15 September 2003.
- 2a) ☐ This action is **FINAL**. 2b) ☒ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

Disposition of Claims

- 4) ☒ Claim(s) 1-74 is/are pending in the application.
- 4a) Of the above claim(s) _____ is/are withdrawn from consideration.
- 5) ☐ Claim(s) _____ is/are allowed.
- 6) ☒ Claim(s) 1-74 is/are rejected.
- 7) ☐ Claim(s) _____ is/are objected to.
- 8) ☐ Claim(s) _____ are subject to restriction and/or election requirement.

Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☐ The drawing(s) filed on _____ is/are: a) ☐ accepted or b) ☐ objected to by the Examiner.
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

Priority under 35 U.S.C. § 119

- 12) ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☐ All b) ☐ Some * c) ☐ None of:
1. ☐ Certified copies of the priority documents have been received.
 2. ☐ Certified copies of the priority documents have been received in Application No. _____.
 3. ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).

* See the attached detailed Office action for a list of the certified copies not received.

Attachment(s)

- | | |
|---|---|
| 1) <input checked="" type="checkbox"/> Notice of References Cited (PTO-892) | 4) <input type="checkbox"/> Interview Summary (PTO-413)
Paper No(s)/Mail Date. _____ |
| 2) <input type="checkbox"/> Notice of Draftsperson's Patent Drawing Review (PTO-948) | 5) <input type="checkbox"/> Notice of Informal Patent Application (PTO-152) |
| 3) <input checked="" type="checkbox"/> Information Disclosure Statement(s) (PTO-1449 or PTO/SB/08)
Paper No(s)/Mail Date <u>11/08/04</u> . | 6) <input type="checkbox"/> Other: _____ |

DETAILED ACTION

Claim Rejections - 35 USC § 102

1. The following is a quotation of the appropriate paragraphs of 35 U.S.C. 102 that form the basis for the rejections under this section made in this Office action:

A person shall be entitled to a patent unless –

(b) the invention was patented or described in a printed publication in this or a foreign country or in public use or on sale in this country, more than one year prior to the date of application for patent in the United States.

Claims 1, 3-4, 6-11, 14-17, 19, 21-26, 29-37, 39-46, 49, 51-58, 60, 62-69 and 71 are rejected under 35 U.S.C. 102(b) as being anticipated by **Sumic (5,568,399)**.

Regarding claims 1, 14, **Sumic** discloses a method of protecting a circuit comprising:

monitoring a zone of protection of the circuit to determine a first topology (Col. 5, lines 59-66; Col. 6, lines 6-30; Figs. 3a-3b); adjusting a zone protective function for said zone of protection based at least in part upon changes to said first topology (Col. 6, lines 58-61, i.e., the protective device schema data structure is dynamically maintained and updated following any changes to the distribution system functional topology during the operation of the power distribution system); and performing said zone protective function on said zone of protection (Col. 41-49);

14. A method of protecting a circuit comprising: monitoring the circuit to determine a first topology (Col. 5, lines 59-66; Col. 6, lines 6-30; Figs. 3a-3b); and defining a zone of protection for at least a portion of the circuit based at least in part upon changes to said first topology (Col. 6, lines 58-61, i.e., the protective device schema data structure is

dynamically maintained and updated following any changes to the distribution system functional topology during the operation of the power distribution system; Col. 6, lines 19-23).

As for claims 29, 39, 51 and 62, **Sumic** further discloses,

29. A protection system for coupling to a circuit having a circuit breaker (Col. 5, lines 17-18), the system comprising: a control processing unit being communicatively coupleable to the circuit (Fig. 2, element 42), so that said control processing unit can monitor a topology of the circuit (Fig. 5A, steps 72, 74), said control processing unit defining a zone of protection for at least a portion of the circuit based at least in part upon said topology (Col. 5, lines 59-66), and said control processing unit redefining said zone of protection based at least in part upon changes to said topology (Col. 6, lines 58-61).

39. A protection system for coupling to a circuit having a zone of protection and a circuit breaker (Col. 5, lines 17-18), the system comprising: a control processing unit being communicatively coupleable to the circuit so that said control processing unit can monitor a topology of the zone of protection (Fig. 2, element 42), said control processing unit adjusting a zone protective function for the zone of protection based at least in part upon said topology (Col. 6, lines 44-61; Col. 6, lines 19-23), and said control processing unit performing said zone protective function to detect a fault in the zone of protection (Col. 5, lines 59-67).

51. A power distribution system comprising: a circuit (Fig 3a); and a control processing unit communicatively coupled to said circuit (Fig. 2, element 42; Col. 5, lines 47-66), wherein said control processing unit determines a topology of said circuit (Col. 5, lines 59-66; Col. 6, lines 6-30; Figs. 3a-3b), wherein said control processing unit defines a zone of protection for at least a portion of said circuit based at least in part upon said topology (Col. 5, lines 59-66), and wherein said control processing unit redefines said zone of protection based at least in part upon changes to said topology (Col. 6, lines 58-61).

62. A power distribution system comprising: a circuit having a zone of protection (Figs 4A —4B); and a control processing unit being communicatively coupled to said circuit (Fig. 2, element 42; Col. 5, lines 47-66), wherein said control processing unit monitors a topology of said zone of protection (Fig. 5A, steps 72, 74), wherein said control processing unit adjusts a zone protective function for said zone of protection based at least in part upon said topology (Col. 6, lines 44-61; Col. 6, lines 19-23), and wherein said control processing unit performs said zone protective function to detect a fault in said zone of protection (Col. 5, lines 59-67).

As for claims 3-4, **Sumic** discloses,

3. The method of claim 1, further comprising determining said first topology based at least in part upon a state for each of a plurality of power switching devices in said zone of protection, said state being either opened or closed (Col. 5, lines 30-34, status of the power grid; Col. 6, lines 1-6, i.e., the distribution system topology used in the outage

determination program describes the function topology or *connectivity* of the power distribution grid).

4. The method of claim 3, further comprising opening at least one of said plurality of power switching devices in said zone of protection based at least in part upon said zone protective function (Col. 5, lines 23-26).

As for claims 6-11, **Sumic** discloses,

6. The method of claim 3, further comprising: monitoring electrical parameters of said zone of protection; and communicating said electrical parameters over a network to a microprocessor (Col. 7, lines 4-13).

7. The method of claim 6, wherein said microprocessor applies an algorithm to said electrical parameters to perform said zone protective function (Figs. 5A-5B).

8. The method of claim 7, wherein said microprocessor uses a coefficient of said algorithm in applying said zone protective function, and wherein said microprocessor adjusts said coefficient based at least in part upon said changes to said first topology (Col. 10, lines 9-47).

9. The method of claim 6, wherein said microprocessor is configured to operate each of said plurality of power switching devices in said zone of protection (Col. 9, lines 35-55).

Art Unit: 2125

10. The method of claim 6, further comprising generating an open command by said microprocessor in response to said electrical parameters, communicating said open command from said microprocessor to an actuator operably connected to at least one of said plurality of power switching devices, and opening said at least one of said plurality of power switching devices in response to said open command (Col. 5, lines 23-28).

11. The method of claim 6, further comprising sensing said electrical parameters with a sensor, communicating signals representative of said electrical parameters to a module, and communicating said signals to said microprocessor, wherein said module, said sensor and said microprocessor are communicatively coupled (Col. 7, lines 4-13).

As for claims 15-17, **Sumic** discloses,

15. The method of claim 14, further comprising detecting a fault in said zone of protection (Col. 5, lines 59-66; Col. 7, lines 25-39).

As for claim 16, the same citations applied to claim 4 above apply as well for this claim.

17. The method of claim 15, further comprising performing a zone protective function on said zone of protection to detect said fault (Col. 7, lines 40-43).

As for claim 19, **Sumic** discloses,

19. The method of claim 17, further comprising: determining said first topology based

Art Unit: 2125

upon a state for each of a plurality of power switching devices in the circuit, said state being either opened or closed; and opening at least one of said plurality of power switching devices based at least in part upon said zone protective function.

As for claims 21-26, the same citations applied to claims 6-11 above apply as well for these claims.

As for claims 30-32, **Sumic** discloses,

30. The system of claim 29, further comprising a network in communication with said control processing unit and the circuit (Fig. 2; Col. 5, lines 47-66).

31. The system of claim 29, wherein said control processing unit operatively controls the circuit breaker (Col. 5, lines 23-28).

32. The system of claim 31, wherein said control processing unit receives parameter signals representative of electrical parameters of the circuit (Col. 7, lines 4-13), and wherein said control processing unit opens the circuit breaker in response to said parameter signals if a fault is detected in the circuit (Col. 5, lines 23-28).

As for claims 33-34, the same citations applied to claims 7-8 above apply as well for these claims.

As for claim 35, **Sumic** discloses,

35. The system of claim 32, wherein said electrical parameters further comprise a state of the circuit breaker, said state being either opened or closed, and wherein said topology is monitored by said control processing unit based at least in part upon said state of the circuit breaker (Col. 5, lines 23-29 and lines 59-66).

As for claims 36-37, 46, 49, 58, 69, and 71 the same citations applied to claims 10-11 above apply as well for these claims.

As for claims 40-42, 52-55, and 63-65, the same citations applied to claims 30-32 above apply as well for these claims.

As for claims 43-44, 57, 60, and 66-67, the same citations applied to claims 7-8 above apply as well for these claims.

As for claim 45, 56, and 68, the same citations applied to claim 35 above apply as well for these claims.

Claim Rejections - 35 USC § 103

2. The following is a quotation of 35 U.S.C. 103(a) which forms the basis for all obviousness rejections set forth in this Office action:

(a) A patent may not be obtained though the invention is not identically disclosed or described as set forth in section 102 of this title, if the differences between the subject matter sought to be patented and the prior art are such that the subject matter as a whole would have been obvious at the time the invention was made to a person having ordinary skill in the art to which said subject matter pertains. Patentability shall not be negated by the manner in which the invention was made.

Claims 2, 5, 18, 20, 38, 50, 59, 61, 70 and 74 are rejected under 35 U.S.C. 103(a) as being unpatentable over **Sumic (5,568,399)** in view of **Finn et al. (US 6,728,205 B1)**.

Sumic discloses the limitations of claims 1, 14-17, 51, and 62 above but fails to disclose the limitations of claims 2, 5, 18, 20, 38, 50, 59, 61, 70 and 74. However, **Finn** discloses such limitations as follows:

As for claim 2,

2. The method of claim 1, further comprising: determining a second topology of the circuit based at least in part upon a state for each of a plurality of power switching devices in the circuit, said state being either opened or closed (Fig. 8, step 194, i.e. Generate more subgraphs? , please note that each subgraph corresponds to a portion of a topology of the circuit; Col. 1, lines 44-49, please note that when link or node in a path fails communication is disrupted corresponds to an open state; and defining said zone of protection based at least in part upon said second topology (Fig. 10, Define reverse subgraph; Fig. 8, step 198, Generate a next subgraph from the remaining network; Col. 18, lines 43-52; Col. 18, lines 55-66).

As for claims 5, 20, 38, 50, 59 and 70, **Finn** discloses determining a dynamic delay time for opening said at least one of said plurality of power switching devices in said zone of protection; and opening said at least one of said plurality of power switching devices in said zone of protection after said dynamic delay time has elapsed Col. 2, lines 58-61; Col. 3, lines 29-34).

As for claim 18,

18. The method of claim 17, further comprising: monitoring a second topology for said zone of protection; and adjusting said zone protection function based at least in part upon changes to said second topology (Fig. 2, each tree corresponds to a topology; Col. 22, lines 54 to Col. 23, lines 27).

As for claims 61 and 74, **Finn** further discloses,

61. The system of claim 51, wherein said circuit comprises a first circuit breaker and a second circuit breaker, said first circuit breaker being downstream of said second circuit breaker, said first circuit breaker having a first current running therethrough and first pickup settings, wherein said control processing unit causes said second circuit breaker to enter a pickup mode as a function of said first current and said first pickup settings when a fault is detected downstream of said first circuit breaker (Figs. 4-4B, Col 22, lines 54-67; Col. 15, lines 57- Col. 16, line 11; please note that any node corresponds to a circuit breaker and when a fault is detected between nodes 1 and 2 then node 8 enters a pickup mode as shown in Fig. 4A)..

Therefore, it would have been obvious to a person of the ordinary skill in the art at the time the invention was made to combine the teachings of **Sumic** with the automatic protection switching system of **Finn** because it would provide an improved system for generating subgraphs on node and edge redundant networks having an

arbitrary network topology when a fault is detected (Abstract; Col. 1, lines 15-20; Col. 6, lines 38-44).

3. Claims 12-13, 27-28, 47-48 and 72-73 are rejected under 35 U.S.C. 103(a) as being unpatentable over **Sumic (5,568,399)** in view of **Tracy Nelson et al. (US 2005/0251296 A1)**.

Sumic discloses the limitations of claims 1, 3, 6, 11, 14, 15, 17, 19, 21, 26, 39, 41, 42, 46, 62, 65, and 71. **Sumic** further discloses adjusting said zone protective functions based upon changes in said topology (See citations of Claim 1). However, **Sumic** does not disclose the limitations of claims 12-13, 27-28, 47-48 and 72-73, but **Tracy** discloses such limitations as follows:

monitoring said sensor to detect an error in sensing said electrical parameters; and adjusting said zone protective function based at least in part upon the detection of said error ([0082], time stamps errors; [0126]);

monitoring said module to detect an error in communicating said signals to said microprocessor; and adjusting said zone protective function based at least in part upon the detection of said error ([0080]-[0081], integrity check; [0087]; [0107]; [0126]).

Therefore, it would have been obvious to a person of the ordinary skill in the art at the time the invention was made to combine the teachings of **Sumic** with the method and apparatus for control of an electric power distribution system in response to circuit abnormalities of **Tracy** because it would provide a more efficiently and flexible system

Art Unit: 2125


to respond to abnormalities to reconfigure and restore service to end customers by including error checking in the system as taught by Tracy (Abstract; [0081-[0087])).

Conclusion

4. The prior art made of record and not relied upon is considered pertinent to applicant's disclosure.

Any inquiry concerning communication or earlier communication from the examiner should be directed to Zoila Cabrera, whose telephone number is (571) 272-3738. The examiner can normally be reached on M-F from 8:00 a.m. to 5:30 p.m. EST (every other Friday).

If attempts to reach the examiner by phone fail, the examiner's supervisor, Leo Picard, can be reached on (571) 272-3749. Additionally, the fax phones for Art Unit 2125 are (571) 273-8300. Any inquiry of a general nature or relating to the status of this application should be directed to the group receptionist at (703) 305-9600.



Zoila Cabrera
Patent Examiner
1/19/06